

TEST REPORT EN 62619

Secondary cells and batteries containing alkaline or other non-acid electrolytes - Safety requirements for secondary lithium cells and batteries, for use in industrial applications

Report Number	: CMC250630011
Date of issue	: 2025-07-28
Total number of pages	: 22 Pages
Tested by (name, signature)	: Jinsheng Li <i>Jinsheng Li</i>
Reviewed by (name, signature)	: Meiko Ma <i>Meiko Ma</i>
Approved by (name, signature)	: Dylan Dou <i>Dylan Dou</i>
Name of Testing Laboratory preparing the Report	: CMC Testing International (Shenzhen) Co., Ltd.
Address	: 1-3/F., Building 7, He'er Hongben Industrial Zone, Dawangshan Community, Shajing Subdistrict, Baoan District, Shenzhen, Guangdong, China
Applicant's name	: Dongguan Seplos Technology Co., Ltd
Address	: 3rd Floor, No.58, Qingzhang Road, Qingxi Town, Dongguan City
Manufacturer's name	: Dongguan Seplos Technology Co., Ltd
Address	: 3rd Floor, No.58, Qingzhang Road, Qingxi Town, Dongguan City
Test specification:	
Standard	: EN IEC 62619: 2022
Test procedure	: Type approved
Non-standard test method	: N/A
Test result	: Pass
Test item description	: Lithium iron phosphate battery pack
Trade Mark	: SEPLUS
Model/Type reference	: MASON-560L-N
Ratings	: 51.2V, 628Ah,32.15KWh

General disclaimer:

The test results presented in this report relate only to the object tested.
This report shall not be reproduced, except in full, without the written approval of the CMC. The authenticity of this Test Report and its contents can be verified by contacting the CMC, responsible for this Test Report.

List of Attachments (including a total number of pages in each attachment):

Attachment 1: Photo documentation (4 pages).

Summary of testing:

Tests performed (name of test clause and test performed):

cl.7.2.3 Drop test (battery system)
cl.8.2.2 Overcharge control of voltage (battery system);
cl.8.2.3 Overcharge control of current (battery system);
cl.8.2.4 Overheating control (battery system)

The component cell (MB31) was evaluated according to IEC 62619-2022 by TÜV Rheinland Ref. Certif. No.: JPTUV-157371

Tests are made with the number of batteries specified in IEC 62619: 2022.

Testing location:

CMC Testing International (Shenzhen) Co., Ltd.
1-3/F., Building 7, He'er Hongben Industrial Zone, Dawangshan Community, Shajing Subdistrict, Baoan District, Shenzhen, Guangdong, China

Summary of compliance with National Differences (List of countries addressed):

The product fulfils the requirements of IEC 62619:2022.

Copy of marking plate:

Rechargeable Li-ion Battery SEPLUS

Model	MASON-560L-N
Indicator name	IFpP73/175/209/[16S]M/0 +60/95
Nominal Voltage/capacity	51.2Vd.c.,628Ah 32.15kWh
Cell Chemistry	LiFePO4
Charge Voltage(V)	58.4Vd.c.
Battery voltage range	43.2~58.4Vd.c.
Max.Charge/Discharge Current	200Ad.c.
Ambient temperature	0~50°C
Protective class	class I
IP rating	IP20
Manufacturer	Dongguan Seplos Technology Co.,Ltd
Production address	Dongguan,CHINA









SE-MS048628L
25/28
0001

Remark:

QR code content example diagram description:



SE-MS048628L



25/28
date)

Production date: 28th week of 2025 (actual production date is updated according to order production

0001

Product serial number

Use of uncertainty of measurement for decisions on conformity (decision rule):

No decision rule is specified by the IEC standard, when comparing the measurement result with the applicable limit according to the specification in that standard. The decisions on conformity are made without applying the measurement uncertainty ("simple acceptance" decision rule, previously known as "accuracy method").

Other: ... (to be specified, for example when required by the standard or client, or if national accreditation requirements apply)

Information on uncertainty of measurement:

The uncertainties of measurement are calculated by the laboratory based on application of criteria given by OD-5014 for test equipment and application of test methods, decision sheets and operational procedures of IECEE.

IEC Guide 115 provides guidance on the application of measurement uncertainty principles and applying the decision rule when reporting test results within IECEE scheme, noting that the reporting of the measurement uncertainty for measurements is not necessary unless required by the test standard or customer.

Calculations leading to the reported values are on file with the NCB and testing laboratory that conducted the testing.

Test item particulars..... :	
Classification of installation and use	To be defined in final system.
Supply Connection.....	Not directly connected mains.
Possible test case verdicts:	
- test case does not apply to the test object.....	N/A
- test object does meet the requirement	P (Pass)
- test object does not meet the requirement	F (Fail)
Testing..... :	
Date of receipt of test item.....	2025-06-30
Date (s) of performance of tests.....	2025-07-03 to 2025-07-14
Test Environment Condition	Ambient temperature: 22.2°C~23.9°C
Sample No.	SN250630011B001
General remarks:	
<p>The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory. "(CXXX)" refers to sample number of cells, "X" is 0~9; "(See Enclosure)" refers to additional information appended to the report. "(See appended table)" refers to a table appended to the report.</p>	
<p>Throughout this report a <input type="checkbox"/> comma / <input checked="" type="checkbox"/> point is used as the decimal separator.</p>	
Name and address of factory (ies)	Same as applicant

General product information and other remarks:

The product for MASON-560L-N are a Rechargeable Lithium iron phosphate battery pack with a nominal voltage of 51.2V which is used in energy storage applications.

The battery consists of 32 pcs Lithium Iron Phosphate cells connected in a 16S2P formation.

The main features of the battery are shown as below:

Product name	Component Cell used inside	LiFePO ₄ Battery
Model Designation	MB31	MASON-560L-N
Rated capacity (Ah)	314	628
Nominal voltage (V)	3.2	51.2
Nominal Charging Current (A)	157	100
Maximum Charging Current (A)	314	200
Nominal Discharge Current (A)	157	100
Maximum Discharging Current (A)	314	200
Charge temperature Range (°C)	0~65	0~55
Discharge temperature Range (°C)	-30~65	-15~55
Recommend Charge voltage(V)	3.65	58.4
Maximum charge voltage(V)	3.65	58.4
Upper limit Charging Voltage (V)	4.0	-
End of discharge voltage (V)	2.5	43.2
Weight (Kg)	5.6±0.3	236
Battery configuration		
Cell in connection	16S2P	
Recommend charging method declared by the manufacturer-Battery system	Charge at constant current 100A until voltage reaches 58.4V, then charge at constant voltage 58.4V till current reduced to 20A.	
Recommend discharging method declared by the manufacturer-Battery system	Discharge at constant current 100A until voltage reaches 43.2V	

EN 62619			
Clause	Requirement + Test	Result - Remark	Verdict
4	PARAMETER MEASUREMENT TOLERANCES		P
	Parameter measurement tolerances		P
5	GENERAL SAFETY CONSIDERATIONS		P
5.1	General		P
	Cells and batteries are safe under conditions of both intended use and reasonably foreseeable misuse...	See also table 5.1 for Critical components information	N/A
	Reduce the risk of injuries from moving parts		P
5.2	Insulation and wiring		P
	Voltage, current, altitude, and humidity requirements		P
	Adequate clearances and creepage distances between connectors and live parts at different voltages or between live parts and non-current-carrying accessible parts		P
	Protect from hazardous live parts, including during installation		N/A
	The mechanical integrity of internal connections		P
5.3	Venting		P
	Pressure relief function		P
	Encapsulation used to support cells within an outer casing		P
5.4	Temperature/voltage/current management		P
	The design prevents abnormal temperature-rise		P
	Voltage, current, and temperature limits of the cells	See above	P
	Specifications and charging instructions for equipment manufacturers	The charging limits specified in the manufacturer's specification.	P
5.5	Terminal contacts of the battery pack and/or battery system		P
	Polarity marking(s)	Battery surface marking "+" "-"	P
	Capability to carry the maximum anticipated current		P
	External terminal contact surfaces	See above	P
	Terminal contacts are arranged to minimize the risk of short circuits		P
5.6	Assembly of cells, modules, or battery packs into battery systems		P
5.6.1	General		P
	Independent control and protection method(s)		P
	Recommendations of cell operating limits, mounting advice, storage conditions and other design recommendations by the cell manufacturer		P
	Batteries designed for the selective discharge of a portion of their series connected cells	No such design.	N/A

EN 62619			
Clause	Requirement + Test	Result - Remark	Verdict
	Protective circuit component(s) and consideration to the end-device application		P
5.6.2	Battery system design		P
	The voltage control function		P
	Maximum charging/discharging current of the cell are not exceeded		P
5.7	Operating region of lithium cells and battery systems for safe use		P
	The cell operating region		P
	Designation of battery system to comply with the cell operating region	Information mentioned in manufacturer's specifications	P
5.8	System lock (or system lock function)		P
	Non-resettable function to stop battery operation		P
	Manual with procedure for resetting of battery operation		P
	Emergency battery final discharge	No such design.	N/A
5.9	Quality plan		P
	Manufacturing quality plan (for example: ISO9001, etc.) prepared and implemented	Complied. Quality control plan provided.	P
	The process capabilities and the process controls		P
6	TYPE TEST CONDITIONS		P
6.1	General		P
6.2	Test items		P
	Cells or batteries that are not more than six months old (See Table 1 of IEC62619)		P
	Capacity confirmation of the cells or batteries		P
	Default ambient temperature of test, 25 °C ± 5 °C		P
7	SPECIFIC REQUIREMENTS AND TESTS		P
7.1	Charging procedure for test purposes		P
	The battery discharged to a specified final voltage prior to charging		P
	The cells or batteries charged using the method specified by the manufacturer	CB Approved Cell	P
7.2	Reasonably foreseeable misuse		N/A
7.2.1	External short-circuit test (cell or cell block)	CB Approved Cell	N/A
	Short circuit with total resistance of 30 mΩ ± 10 mΩ at 25 °C ± 5 °C		N/A
	Results: no fire, no explosion		N/A
7.2.2	Impact test (cell or cell block)	CB Approved Cell	N/A
	Cylindrical cell, longitudinal axis impact		N/A

EN 62619			
Clause	Requirement + Test	Result - Remark	Verdict
	Prismatic cell, longitudinal axis and lateral axis impact		N/A
	Results: no fire, no explosion.		N/A
7.2.3	Drop test (cell or cell block, and battery system)		P
7.2.3.1	General		P
7.2.3.2	Whole drop test (cell or cell block, and battery system)		N/A
	Description of the Test Unit..... :		—
	Mass of the test unit (kg)..... :		—
	Height of drop (m)..... :		—
	Results: no fire, no explosion		N/A
7.2.3.3	Edge and corner drop test (cell or cell block, and battery system)		P
	Description of the Test Unit..... :	Battery system	—
	Mass of the test unit (kg)..... :	236kg	—
	Height of drop (m)..... :	0.025m	—
	Results: no fire, no explosion		P
7.2.4	Thermal abuse test (cell or cell block)	CB Approved Cell	N/A
	Results: no fire, no explosion		N/A
7.2.5	Overcharge test (cell or cell block)	CB Approved Cell	N/A
	For those battery systems that are provided with only a single protection for the charging voltage control		—
	Results: no fire, no explosion..... :		N/A
7.2.6	Forced discharge test (cell or cell block)	CB Approved Cell	N/A
	Cells connected in series in the battery system..... :		N/A
	Redundant or single protection for discharge voltage control provided in battery system..... :		N/A
	Target Voltage..... :		-
	Maximum discharge current of the cell, I_m :		-
	Discharge current for forced discharge, 1.0 I_t :		-
	Discharging time, $t = (1 I_t / I_m) \times 90$ (min.)..... :		-
	Results: no fire, no explosion..... :		N/A
7.3	Considerations for internal short-circuit – Design evaluation		N/A
7.3.1	General		N/A
7.3.2	Internal short-circuit test (cell)	CB Approved Cell	N/A
	Samples preparation procedure: In accordance with Clause A.5 and A.6 of IEC 62133-2:2017		N/A
	Tested per 7.3.2 b) in an ambient temperature of $25\text{ °C} \pm 5\text{ °C}$.		N/A

EN 62619			
Clause	Requirement + Test	Result - Remark	Verdict
	The appearance of the short-circuit location recorded by photograph or other means		-
	The pressing was stopped - When a voltage drop of 50 mV was detected; or		N/A
	- The pressing force of 800 N (cylindrical cells) or 400 N (prismatic cells) was reached		N/A
	Results: no fire, no explosion		N/A
7.3.3	Propagation test (battery system)		N/A
	Method to create a thermal runaway in one cell ... :	Alternate, 7.3.2 for cell have tested.	N/A
	Results: No external fire from the battery system or no battery case rupture		N/A

8	BATTERY SYSTEM SAFETY (CONSIDERING FUNCTIONAL SAFETY)		P
8.1	General requirements		P
	Functional safety analysis for critical controls		N/A
	Conduct of a process hazard analysis for both the cell manufacturing process and the battery system manufacturing process		N/A
	Conduct of risk assessment and mitigation of the battery system		N/A
8.2	Battery management system (or battery management unit)		P
8.2.1	Requirements for the BMS		P
	The safety integrity level (SIL) target of the BMS		N/A
	The charge control evaluated by tests in clauses 8.2.2 to 8.2.4		P
8.2.2	Overcharge control of voltage (battery system)		P
	The exceeded charging voltage applied to the whole battery system		P
	The exceeded charging voltage applied to only a part of the battery system, such as the cell(s)		N/A
	Results: no fire, no explosion	See Table 8.2.2	P
	The BMS terminated the charging before exceeding the upper limit charging voltage		P
8.2.3	Overcharge control of current (battery system)		P
	Results: no fire, no explosion	See Table 8.2.3.	P
	The BMS detected the overcharging current and controlled the charging to a level below the maximum charging current		P
8.2.4	Overheating control (battery system)		P
	The cooling system, if provided, was disconnected	No cooling system	N/A
	Elevated temperature for charging, 5 °C above maximum operating temperature		P

EN 62619			
Clause	Requirement + Test	Result - Remark	Verdict
	Results: no fire, no explosion	See Table 8.2.4.	P
	The BMS detected the overheat temperature and terminated charging		P
	The battery system operated as designed during test	Complied.	P

9	EMC		N/A
	Battery system fulfil EMC requirements of the end-device application		N/A

10	MARKING AND DESIGNATION (REFER TO CLAUSE 5 OF IEC 62620)		P
	The cell manufacturer provides information about current, voltage and temperature limits of their products		P
	The battery system manufacturer provides information regarding how to mitigate hazards to equipment manufacturers or end-users.		P

11	MARKING AND DESIGNATION (REFER TO CLAUSE 5 OF IEC 62620)		P
	The marking items shown in Table 1 in IEC 62620 indicated on the cell, battery system or instruction manual.		P
	Cell or battery system has clear and durable markings		P
	Cell designation	The final product is battery	N/A
	Battery designation	IFpP/73/175/208/[16S2P]M/0+60/95	P
	Battery structure formulation	16S2P	P

12	PACKAGING AND TRANSPORT		N/A
	Refer to Annex D	Informative.	N/A

ANNEX A	OPERATING REGION OF CELLS FOR SAFE USE		N/A
A.1	General		N/A
A.2	Charging conditions for safe use		N/A
A.3	Consideration on charging voltage		N/A
A.4	Consideration on temperature		N/A
A.5	High temperature range		N/A
A.6	Low temperature range		N/A
A.7	Discharging conditions for safe use		N/A
A.8	Example of operating region		N/A

EN 62619			
Clause	Requirement + Test	Result - Remark	Verdict

ANNEX B	PROCEDURE OF 7.3.3 PROPAGATION TEST BY LASER IRRADIATION		N/A
B.1	General		N/A
B.2	Test conditions:		N/A
	The cell fully charged according to the manufacturer recommended conditions		—
	Laser irradiation point on the cell		—
	Output power of laser irradiation		—
	Repeat of cell test for 3 times		N/A
B.2.2	Battery system test (main test)		N/A
	The battery system fully charged according to the manufacturer recommended conditions		N/A
	Target cell to be laser irradiated.....		—
	The irradiation point on the target cell same or similar as that on the cell test		N/A
	Output power of laser irradiation		—
	Tested in an ambient temperature of 25 °C ± 5 °C		N/A

ANNEX C	PROCEDURE OF 7.3.3 PROPAGATION TEST BY METHODS OTHER THAN LASER		N/A
C.1	General		N/A
C.2	Test conditions:		N/A
	– The battery fully charged according to the manufacturer recommended conditions		—
	– Target cell forced into thermal runaway		—
	– A specially prepared sample (e.g. a heater or a hole for nail penetration provided) used for ease of testing.....		—
C.3	Method used for initiating the thermal runaway. 1) Heater (Heater, Burner, Laser, Inductive heating 2) Overcharge 3) Nail penetration of the cell 4) Combination of above methods 5) Other methods.....		—

ANNEX D	PACKAGING AND TRANSPORT		N/A
	The materials and pack design chosen in a way as to prevent the development of unintentional electrical conduction, corrosion of the terminals and ingress of environmental contaminants		N/A
	Regulations concerning international transport of secondary lithium batteries		N/A

5.1	TABLE: Critical components information					P
Object/part no.	Manufacturer/ trademark	Type/model	Technical data	Standard	Mark(s) of conformity 1)	
Cell	EVE Power Co., Ltd.	MB31	3.2V, 314Ah	IEC 62619: 2022	TÜV Rheinland Ref. Certif. No.: JPTUV- 157371	
PCB	Kunshan Feifan Electronic Co.,Ltd	FF-M	V-0, 130°C	UL94, UL 796	UL E345969	
MOS (QD1, QD2, QD3, QD4, QD5, QD6', QD7', QD8, QD9, QD10)	CR MICRO	NCEP039N10MD	VDS:100V, VGS: ±20V, ID:135A, TJ: -55- 175°C	IEC 62619: 2022	Tested with appliance	
MOS (QC1, QC2, QC3, QC4, QC5, QC6, QC7, QC8, QC9 , QC10)	CR MICRO	NCEP039N10MD	VDS:100V, VGS: ±20V, ID:135A, TJ: -55- 175°C	IEC 62619: 2022	Tested with appliance	
MOS(Q60, Q61)	CR MICRO	CRTS120N15N	VDS:100V, VGS: ±20V, ID:119A, TJ: -55- 150°C	IEC 62619: 2022	Tested with appliance	
NTC (NTC1, NTC2, NTC3, NTC4, N1, N2)	Nanjing Shiheng Electronic Technology Co., Ltd	MF52C- 103Y3435	10kohm at 25°C	UL 1434	UL E240991	
MCU (U2)	GigaDevice	GD32F307VCT6	Supply voltage: 3V- 3.3V, -40°C~85°C	IEC 62619: 2022	Tested with appliance	
IC (U1)	Sino Wealth	SH367309	VDD: Max 70V, - 40~85°C	IEC 62619: 2022	Tested with appliance	
Wire	SHENZHEN SHUNJIA ELECTRICAL TECHNOLOGY CO LTD	1283	2AWG, 105°C	UL 758	UL E490463	
Metal enclosure	Shenzhen Chuansheng Hardware Electromechanical Co., LTD	MASON-560L-N	Min. thickness: 1.5mm, Dimensions: (416*560*910)mm	--	Tested with appliance	
Connector (P+)	DEGSON TECHNOLOGY CO., LTD.	EGD-300A-B95- B/S-OR-00	Rated voltage:1500V DC Rated current:300A	UL-1059	UL E228872	
Connector (P-)	DEGSON TECHNOLOGY CO., LTD.	EGD-300A-B95- B/S-BK-00	Rated voltage:1500V DC Rated current:300A	UL-1059	UL E228872	

Insulating Board	SICHUAN DONGFANG INSULATING MATERIAL CO., LTD	DFR117ECOB	BK, 80°C, V-0, Thickness:0.5mm	UL 94 IEC 60695 UL 746	UL E199019
Signal Wire	DONGGUAN TENGDA WIRE CO LTD	1332	20AWG, 200°C, 300VAC	UL758	UL E503909
U21	GigaDevice	GD32FCESRBT6	Supply voltage:2.6V~3.6V , -40°C~85°C	IEC 62619: 2022	Tested with appliance
QF	SHANGHAI LIANGXIN ELECTRICAL CO LTD	NDB3-100	<i>Rated current: 250A</i> DC80V	UL 1077 UL 489	E300669 E310211
IC(U1, U3, U4, U7, U8, U9, U10, U11, U12, U13, U14, U15, U16, U17, U18, U19)	VPSC	VPS2608	Supply voltage:4V~10V , -40°C~125°C	IEC 62619: 2022	Tested with appliance
Bluetooth (U24)	HiLink	HLX-B40	Supply voltage: 1.8~4.2V, temperature: -40°C~+105°C	IEC 62619: 2022	Tested with appliance
IC (U23)	Novosense	NSI83085E-DSWR	Max input voltage VDD1, VDD2 6V, operating temperature -40~105°C	IEC 62619: 2022	Tested with appliance
IC(U13)	UTC	LR1107G-33-AE3-3-R	input voltage range: 2.5V-7V, output voltage range:1.145V-5V, operating temperature -40~125°C	IEC 62619: 2022	Tested with appliance
TR1, TR2, TR3, TR4, TR5, TR6, TR7, TR8, TR9, TR10, TR11, TR12, TR13, TR14, TR15, TR16	VPSC	VPE68BMS15A	Supply voltage: 40~60V, temperature: -40°C~+85°C	IEC 62619: 2022	Tested with appliance

Supplementary information:

 1) **Provided evidence ensures the agreed level of compliance.**

7.2.1	TABLE: External short-circuit test (cell or cell block)					N/A
Sample No.	Ambient (at 25°C ± 5°C)	OCV at start of test (V dc)	Resistance of Circuit (mΩ)	Maximum Case Temperature Rise ΔT (°C)	Results	
Supplementary information: - No fire or Explosion						

7.2.5	TABLE: Overcharge test (cell or cell block)					N/A
Sample No.	OCV at start of test (V dc)	OCV at end of test (V dc)	Measured Maximum Charging Current (A)	Measured Maximum Charging Voltage (V dc)	Max. Cell Case Temperature, (°C)	Results
Supplementary information: - No fire or Explosion						

7.2.6	TABLE: Forced discharge test (cell or cell block)				N/A
Sample No.	OCV before applying reverse charge, (V dc)	Target Voltage (V dc)	Measured Reverse Charge Current I_t , (A)	Total Time for Reversed Charge Application (min)	Results
Supplementary information: - No fire or Explosion					

7.3.2	TABLE: Internal short-circuit test (cell)				N/A
Sample no.	OCV at start of test, (V dc)	Particle location ¹⁾	Maximum applied pressure, (N)	Results	
Supplementary information:					

7.3.3	TABLE: Propagation test (battery system)				N/A
Sample No.	OCV of Battery System Before Test, (V dc)	OCV of Target Cell Before Test, (V dc)	Maximum Cell Case Temperature, (°C)	Maximum DUT Enclosure Temperature, (°C)	Results
-	-	-	-	-	-
Method of cell failure ¹⁾		Location of target cell		Area for fire protection (m ²)	
-		-		-	
Supplementary information:					

8.2.2	TABLE: Overcharge control of voltage (battery system)				P
Sample No.	OCV at start of test for Cell/Cell Blocks, (V dc)	Maximum Charging Current, (A)	Max. Charging Voltage, (V dc)	Max. Voltage of Cell/Cell Blocks, (V dc)	Results
SN250630011B 001	2.920~3.000	200	3.537	55.401	P
			Charge Voltage Applied Battery System: 1)		
			Whole		Part
			70.4		--
Supplementary information:					
¹⁾ The exceeded voltage can be applied to only a part of the system such as the cell(s) in the battery system per Figure 6 of IEC 62619, if it is difficult to do it in using the whole battery system.					
Results: <ul style="list-style-type: none"> - No Fire or Explosion - The voltage of the measured cells or cell blocks did not exceed the upper limit charging voltage - All function of battery system did operate as intended during the test 					

8.2.3 TABLE: Overcharge control of current (battery system)				P
Sample No.	OCV at start of test, (V dc)	Max. Charging Current, (A)	Max. Charging Voltage, (V dc)	Results
SN250630011B001	47.154	240	48.363	P
Supplementary information:				
Results:				
<ul style="list-style-type: none"> - No fire or Explosion - Overcurrent sensing function of BMU did operate and then charging stopped - All function of battery system did operate as intended during the test 				

8.2.4 TABLE: Overheating control (battery system)				P
Model No.	OCV at start (SOC 50%) of test, V dc	Maximum Charging Current, A	Measured maximum Charging Voltage, V dc	
SN250630011B001	53.168	200	54.253	
Maximum Specified Temperature of Battery System, °C		Maximum Measured Cell Case Temperature, °C	Results	
55		55.4	--	
Supplementary information:				
<ul style="list-style-type: none"> - No fire or Explosion - Temperature sensing function of BMU did operate and then charging stopped - All function of battery system did operate as intended during the test 				


Attachment 1: Photo documentation




Picture 1. Front view of Battery




Picture 2. Back view of Battery




Picture 3. Front view of PCB




Picture 4. Front view of PCB




Picture 5. Back view of PCB



Picture 6. Back view of PCB



Picture 7. Front view of cell



Picture 8. Back view of cell

Important

1. The test report is invalid if it is not affixed the official seal of the laboratory to it.
2. Copies of the test report without the official seal of the laboratory are invalid.
3. It is forbidden to copy the test report partially without the written approval of the laboratory.
4. The test report is invalid without the signatures of Approver, Reviewer and Testing engineer.
5. The test report is invalid if it is blotted out.
6. Objections to the test report must be submitted to CMC within 15 days.
7. The test report is valid for the tested samples only.
8. As for the Verdict, “-” means “no need for judgement”, “P” means “pass”, “F” means “fail” and “N/A” means “not applicable”.

Testing laboratory: CMC Testing International (Shenzhen) Co., Ltd.

Address: 1-3/F., Building 7, He'er Hongben Industrial Zone, Dawangshan Community, Shajing
Subdistrict, Baoan District, Shenzhen, Guangdong, China

Tel: 400-1668-320

E-mail: info@cmczj-lab.com

<http://www.cmczj-lab.com>

-- End of Report --